



*City of* **Tonganoxie**  
**Department of Administration**  
**Office of the Building Official**

321 S. Delaware, P.O. Box 326  
Tonganoxie, KS 66086  
(913) 845-2620  
E-mail: [info@tonganoxie.org](mailto:info@tonganoxie.org)

## Insulation Inspection

THERE WILL BE NO INSULATION INSPECTION UNTIL FURTHER NOTICE.

IMPORTANT PLEASE READ THE FOLLOWING!

At rough frame inspection or at batt insulation install, prior to drywall placement, there will be a fire blocking inspection to check that all penetrations at top and bottom plates are sealed and that other fire blocking requirements are met. Also to inspect that air leakage requirements per 2003 IRC 11.1.10 are met.

The insulation installer shall provide a statement of the R values of the insulation installed.

The requirements stated at the 2003 IRC 1101.3.1 will be inspected at final inspection. 1101.3.1 States that, "Where blown-in insulation is applied in the roof-ceiling assembly, the installer shall provide a certification of the initial installed thickness, coverage area, and number of bags of insulating material installed. Markers shall be provided for every 300 square feet of attic area, attached to the trusses, rafters, or joists, and indicate in 1-inch-high numbers the installed thickness of insulation."

Thank You,

Jerry Hammerton  
Building Official  
(913) 203-9389